



Typical magnetic lock installation for single door shown with keypad & push button for free exit

- Typical power supply 12VDC (min 1 Amp)
- check all devices accept same input voltage
- Keypad shown with typical negative triggered Request To Exit - check keypad user manual as wiring of button may differ
- NC / NO / COM contacts on Mag Lock are to indicate lock status (e.g. with LED) - do NOT connect to Keypad

Saunderson Security - Discounting locks, not your safety.

South Africa: www.saundersonsecurity.co.za sales@saundersonsecurity.co.za T: 0800 204 563
 United Kingdom: www.saundersonsecurity.co.uk sales@saundersonsecurity.co.uk T: 0845 299 0650
 United States: www.saundersonsecurity.com sales@saundersonsecurity.com T: 302-703-0368

WD-ML01

REV01